



Loudoun County, Virginia

Department of Management and Financial Services
Division of Procurement
P.O. Box 7000, Leesburg, Virginia 20177-7000
www.loudoun.gov/purchasing

January 2, 2008

NOTICE TO BIDDERS

ADDENDUM NO. 1

QQ-01377

The following changes and/or additions shall be made to the original Invitation for Bid No. QQ-01377, Preventative Maintenance and Repair Services for Compressed Breathing Air Systems. Please acknowledge receipt of this addendum by signing and returning with your proposal.

1. Section 5.1.D shall be replaced with:
Contractor shall provide air-quality testing to N.F.P.A. and O.S.H.A, Grade "E" air-quality requirements.
2. Section 5.4.B shall have the following sentenced added to the second paragraph:
The Contractor shall have a list of authorized representative presented to themat the kick-off meeting before the contract begins.
3. The Listing of Compressors and tanks shall be replaced with Attachment 1 from this addendum.
4. Please find below answers to question asked during the Pre-Bid Conference.
 - Q. What is the present value of this contract?
 - A. The County has spent approximately \$25,000 so far this fiscal year under this contract.
 - Q. Section 5.3 can you tell me what type of authorization is required for repairs?
 - A. If it is a minor repair, verbal authorization is sufficient. If it is a major repair a written quote must be provided.

Q. Section 5.1.E how many air storage require hydrostatic testing this year?

A. After checking the tanks, there are no DOT Cylinders that require scheduled testing in the upcoming year due to last five year test, however, if any tanks are physically damaged due to unforeseen events they would need to be tested in the upcoming year.

Prepared By: Philip Butterfass /s/
Contracting Officer

Date: January 2, 2008

Acknowledged By: _____ Date: _____